


ISA-75.07-1997

Formerly ISA-S75.07-1997



Laboratory Measurement of Aerodynamic Noise Generated by Control Valves



**ISA—The Instrumentation,
Systems, and
Automation Society**

Approved 31 August 1997

ISA-75.07-1997, Laboratory Measurement of Aerodynamic Noise Generated by Control Valves

ISBN: 1-55617-653-8

Copyright © 1997 by the Instrument Society of America. All rights reserved. Printed in the United States of America. No part of this publication may be reproduced, stored in a retrieval system, or transmitted, in any form or by any means (electronic, mechanical, photocopying, recording, or otherwise), without the prior written permission of the Publisher.

ISA
67 Alexander Drive
P. O. Box 12277
Research Triangle Park, North Carolina 27709

Preface

This preface, as well as all footnotes and annexes, is included for information purposes only and is not part of ISA-75.07-1997.

This Standard has been prepared as part of the service of ISA, the international society for measurement and control, toward a goal of uniformity in the field of instrumentation. To be of real value, this document should not be static but should be subject to periodic review. Toward this end, the Society welcomes all comments and criticisms and asks that they be addressed to the Secretary, Standards and Practices Board, ISA; 67 Alexander Drive; P.O. Box 12277; Research Triangle Park, NC 27709; Telephone (919) 990-9227; Fax (919) 549-8288; Internet: standards@isa.org.

The ISA Standards and Practices Department is aware of the growing need for attention to the metric system of units in general, and the International System of Units (SI) in particular, in the preparation of instrumentation standards, recommended practices, and technical reports. The Department is further aware of the benefits to USA users of ISA standards of incorporating suitable references to the SI (and the metric system) in their business and professional dealings with other countries. Toward this end, this Department will endeavor to introduce SI-acceptable metric units in all new and revised standards to the greatest extent possible. *Standard for Use of the International System of Units (SI): The Modern Metric System*, published by the American Society for Testing & Materials as IEEE/ASTM SI 10-97, and future revisions, will be the reference guide for definitions, symbols, abbreviations, and conversion factors.

It is the policy of the ISA to encourage and welcome the participation of all concerned individuals and interests in the development of ISA standards, recommended practices, and technical reports. Participation in the ISA standards-making process by an individual in no way constitutes endorsement by the employer of that individual, of ISA, or of any of the standards that ISA develops.

Caution

The use of this standard may involve hazardous materials, operations, or equipment. The standard cannot anticipate all possible applications or address all possible safety issues associated with use in hazardous conditions. The user of this standard must exercise sound professional judgment concerning its use and applicability under the user's particular circumstances. The user must also consider the applicability of any governmental regulatory limitations and established safety and health practices before implementing this standard.

Additionally, implementation of the standard may require use of techniques, processes, or materials covered by patent rights. ISA takes no position on the existence or validity of any patent rights which may be involved in implementing the standard. ISA will not be responsible for identifying all patents that may require a license before implementation of the standard or for investigating the validity or scope of any patents brought to its attention. The user should carefully investigate relevant patents before using the standard for the user's intended application.

The following people served as members of ISA Subcommittee SP75.07:

NAME	COMPANY
C. Langford, Chairman	Consultant
W. Weidman, Managing Director	Parsons Energy & Chemical Group
G. Barb	Consultant
H. Baumann	H. D. Baumann Inc.
S. Boyle	Neles Controls, Inc.
*R. Brodin	Fisher Controls International, Inc.
B. Broxterman	Jordan Valve
*A. Fagerlund	Fisher Controls International, Inc.
A. Gharabegian	Engineering-Science
A. Glenn	Valtek International
R. Kassing	Daniel Valve Company
C. Koloboff	Consultant
L. Mariam	FlowSoft, Inc.
H. Miller	Control Components Inc.
T. Molloy	CMES
K. Ng	Office of Naval Research
W. Rahmeyer	Utah State University
J. Reed	Norriseal
G. Reetho	Consultant
J. Reid	Cashco, Inc.
C. Richard	Mobil Oil Company
A. Shea	Copes-Vulcan, Inc.
E. Skovgaard	Leslie Controls, Inc.
R. Tubbs	Industrial Valve & Gauge Company
J. Wang	Exxon Company USA

The following people served as members of ISA Committee SP75:

NAME	COMPANY
*D. Buchanan, Chairman	Union Carbide Corporation
W. Weidman, Managing Director	Parsons Energy & Chemical Group
*T. Abromaitis	Red Valve Company, Inc.
J. Addington	Fluid Controls Inst.
H. Backinger	J. F. Kraus & Company
G. Baenteli	Bechtel
G. Barb	Consultant
H. Baumann	H. D. Baumann Inc.
K. Black	Cashco, Inc.
H. Boger	Masoneilan/Dresser
G. Borden, Jr.	Consultant
S. Boyle	Neles Controls, Inc.
R. Brodin	Fisher Controls International, Inc.
F. Cain	Flowserve-FCD

*One vote per company

C. Corson
 *C. Crawford
 L. Driskell
 *J. Duhamel
 A. Engels
 H. Fuller
 *J. George
 M. Glavin
 L. Griffith
 B. Hart
 F. Harthun
 B. Hatton
 R. Jeanes
 C. Koloboff
 G. Kovacs
 C. Langford
 A. Libke
 R. Louviere
 O. Lovett, Jr.
 J. McCaskill
 A. McCauley, Jr.
 R. McEver
 H. Miller
 T. Molloy
 L. Ormanoski
 J. Ozol
 W. Rahmeyer
 J. Reed
 *G. Richards
 M. Riveland
 K. Schoonover
 A. Shea
 E. Skovgaard
 H. Sonderegger
 R. Terhune
 R. Tubbs
 D. Wolfe

Fluor Daniel, Inc.
 Union Carbide Corporation
 Consultant
 Red Valve Company, Inc.
 Praxair
 Consultant
 Richards Industries, Inc.
 Grinnell Corporation
 Consultant
 M. W. Kellogg, Company
 Consultant
 Honeywell, Inc.
 TU Electric
 Consultant
 Yarway Corporation
 Consultant
 DeZurik Valve Company
 Creole Engineering Sales Company
 Consultant
 Keystone Vales & Controls
 Chagrin Valley Controls, Inc.
 Bettis Corporation
 Control Components, Inc.
 CMES
 Frick Company
 Commonwealth Edison
 Utah State University
 Norriseal
 Richards Industries, Inc.
 Fisher Controls International, Inc.
 Con-Tek
 Copes-Vulcan, Inc.
 Leslie Controls, Inc.
 Grinnell Corporation
 Cranmoor
 Industrial Valve & Gauge Company
 Agren-Ascher Company, Inc.

This Standard was approved for publication by the ISA Standards and Practices Board on August 31, 1997.

NAME

COMPANY

R. Webb, Vice President
 H. Baumann
 D. Bishop
 P. Brett
 W. Calder III
 M. Cohen
 H. Dammeyer
 W. Holland
 H.S. Hopkins

Pacific Gas & Electric Company
 H. D. Baumann, Inc.
 Chevron Production Technology
 Honeywell, Inc.
 Calder Enterprises
 Senior Flexonics, Inc.
 The Ohio State University
 Southern Company Services Inc.
 Utility Products of Arizona

A. Iverson
 K. Lindner
 V. Maggioli
 T. McAviney
 A. McCauley, Jr.
 G. McFarland
 E. Montgomery
 D. Rapley
 R. Reimer
 J. Rennie
 W. Weidman
 J. Weiss
 J. Whetstone
 M. Widmeyer
 H. Wiegler
 C. Williams
 G. Wood
 M. Zielinski

Ivy Optiks
 Endress + Hauser GmbH + Company
 Feltronics Corporation
 Instrumentation & Control Engineering, LLC
 Chagrin Valley Controls, Inc.
 Honeywell, Inc.
 Fluor Daniel, Inc.
 Rapley Engineering Services, Inc.
 Rockwell Automation AB
 Factory Mutual Research Corporation
 Parsons Energy & Chemical Group
 Electric Power Research Institute
 National Inst. of Standards & Technology
 Carnegie Mellon University
 Canus Corp.
 Eastman Kodak Company
 Graeme Wood Consulting
 Fisher•Rosemount

Contents

1 Scope	9
2 Purpose	9
3 Test system	9
3.1 Throttling valves	9
3.2 Test specimen	9
3.3 Test section piping	11
3.4 Pressure taps	12
3.5 Acoustic environment	12
3.6 Instrumentation	13
4 Testing procedures	13
4.1 Fluid	13
4.2 Microphone position	13
4.3 Optional tests	13
4.4 Blowdown test limitation	14
5 Test data	14
Annex A — References	17

Figures

1 — Control valve noise test — system components	10
2 — Test arrangement for test specimen outside test chamber	11
3 — Test arrangement for test specimen inside test chamber	12

1 Scope

This standard defines equipment, methods, and procedures for the laboratory testing and measurement of airborne sound radiated by a compressible fluid flowing through a control valve and its associated piping, including fixed-flow restrictions. The test may be conducted under any conditions mutually agreed upon by the user and the manufacturer. Although this standard is designed for measurement of the noise radiated from the piping downstream of the valve, other test variations are optional, including the use of insulation and nonstandard piping. [\(See 4.3.\)](#) Applications of this standard to control valves discharging directly to atmosphere are excluded from this standard.

2 Purpose

The purpose of this standard is to provide a procedure for testing, measuring, and reporting the aerodynamic noise-generating characteristics of a control valve and its associated piping.

3 Test system

The test system is shown in [Figures 1, 2, and 3](#). The various parts are described below.

3.1 Throttling valves

The upstream and/or downstream throttling valves (optional) are used to regulate the test pressures. Caution should be taken to avoid pressure drops which will create significant stream-borne noise. If such pressure drops are unavoidable, then silencers must be used.

3.2 Test specimen

The test specimen is any valve, combination of valves, fixed restrictions, and associated piping components for which data are required. The test specimen and test section shall not be insulated, although optional tests may be conducted to determine the effect of insulation. [\(See 4.3.\)](#)




Figure 1 — Control valve noise test — system components




Figure 2 — Test arrangement for test specimen outside test chamber

3.3 Test section piping


There is no limitation concerning the maximum length of upstream and downstream piping connected to the test specimen. The exposed pipe within the acoustic environment shall be a minimum of 2.0 meters (m) in length, free of mechanical joints except for the connections between the test specimen and test section (upstream or downstream pipe, depending upon the test conducted). Piping for each side of the test section shall be ANSI Schedule 40 steel pipe for valves through 10 inches (250 mm) body size, having pressure ratings up to ANSI Class 600. Pipe having 0.375 inches (10 mm) wall thickness shall be used for sizes ranging from 12 inches (300 mm) through 24 inches (600 mm).

An effort should be made to match the test specimen inlet and outlet inside diameters with those of the adjacent piping for valve sizes exceeding the above-mentioned limits. Un-insulated pipe

shall be used. Other pipe schedules, pipe materials, or insulated piping may be used for optional tests. (See 4.3.)

3.4 Pressure taps

Pressure taps shall be provided for the measurement of pressures, and the taps shall conform to ANSI/ISA-S75.02-1996, *Control Valve Capacity Test Procedures*, 3.6.



NOTES:

1. THE MICROPHONE SHALL BE LOCATED AT A DISTANCE OF 1.0 m FROM THE OUTER SURFACE OF THE PIPE AND SHALL BE NO CLOSER THAN 0.5 m FROM THE NEAREST CHAMBER SURFACE.
2. SEE 4.2. THE TEST SECTION AND TEST SPECIMEN SHOULD BE AS CLOSELY COUPLED AS PHYSICALLY POSSIBLE.

Figure 3 — Test arrangement for test specimen inside test chamber

3.5 Acoustic environment

The test environment shall be controlled such that background noise, reflected noise, and other extraneous noise sources are at a minimum of 10 dB lower than the noise radiated by the test section. Depending upon the test system and the acoustic environment, upstream and/or downstream silencers may be necessary. General recommendations for the acoustic

environment can be found in ANSI -S1.13-1971(R1986), *Methods for the Measurement of Sound Pressure Levels*. No sound-level correction shall be made for excessive sound levels caused by the test system, the acoustic environment, or other reasons.

3.6 Instrumentation

The instrumentation for sound-level measurements shall conform to ANSI-S1.13-1971(R 1986), Section 5, entitled *Instrumentation for Noise Measurements*. Specifications for sound-level meters shall conform to ANSI-S1.4-1983, *Specification for Sound Level Meters*. Calibration and sensitivity checks shall be corrected for atmospheric pressure to sea level conditions. Accuracy of flow, pressure, and temperature measurements shall conform to ANSI/ISA-S75.02-1996, *Control Valve Capacity Test Procedures*.

4 Testing procedures

4.1 Fluid

Air is the preferred test fluid to be used, but other compressible fluids may be substituted where need and availability dictate. The fluid shall be sufficiently dry to ensure that any icing which may take place does not significantly affect the test results. Saturated vapors are not acceptable as test fluids unless data are required for application to the particular saturated vapor.

4.2 Microphone position

The microphone shall be located 1.0 m away from the nearest pipe surface and oriented per the manufacturer's specifications to measure the noise coming from the pipe. Downstream location shall be 1.0 m from the beginning of the exposed part of the test section, or six nominal pipe diameters downstream of the test specimen outlet, whichever is greater. For test specimens having multiple flow passages, the six pipe diameters may be changed to ten hydraulic diameters of the largest single-flow passage of the test specimen. (For any cross section, Hydraulic Diameter $D = 4 \times \text{Hydraulic Radius}$, or $4 \times \text{Area/Wetted Perimeter}$.)

4.3 Optional tests

Additional tests may be conducted to evaluate nonstandard factors. These tests shall be conducted to otherwise concur with the parameters of this standard. Any exceptions shall be noted in the test data.

4.4 Blowdown test limitation

Blowdown test results are intended to simulate steady-state test results. As a guideline, the difference between the blowdown test results and the steady-state test results should not exceed 2 dB, for equivalent flow conditions. Such assurance of accuracy could be established mathematically, or through a small-scale demonstration test. The blowdown rate shall be limited to conform with ANSI-S1.13-1971(R1986), *Methods for the Measurement of Sound Pressure Levels*, Section 2, Definitions, and shall not exceed the transducer response and data acquisition capabilities of the instrumentation system. In the blowdown method of testing, the inlet pressure to the test specimen decays during the test period. The blowdown rate is the rate at which the inlet pressure to the test specimen changes.

5 Test data

The minimum data to be recorded and reported are as follows:

- 1) upstream pressure;
- 2) pressure drop (ΔP) and/or downstream pressure;
- 3) upstream fluid temperature;
- 4) flow rate;
- 5) valve travel (percent of full travel $\pm 2\%$);
- 6) valve C_v at the test travel positions(s);
- 7) acoustic data consisting of the "A-weighted" source level and either a 1/3-octave or full-octave band analysis which shall be recorded over the frequency range of 180 Hz (250 Hz for full-octave band, or 200 Hz for 1/3-octave band center frequency) to 22 400 Hz (16 000 Hz for full-octave band, or 20 000 Hz for 1/3-octave band center frequency). Narrowband data may be obtained when further frequency resolution is desired.
- 8) description of the complete test specimen;
- 9) description of the test facility, including:
 - a) piping and instrumentation schematic, including the pipe size, material, and wall thickness;
 - b) description of the environmental chamber (if used); and

- c) dimension sketch of the test facility.
- 10) test fluid and its molecular weight or specific gravity;
- 11) instruments used (manufacturer, model number, span, accuracy specification);
- 12) microphone position; and
- 13) any deviations from this standard.

Annex A — References

AMERICAN NATIONAL STANDARDS INSTITUTE (ANSI)

ANSI-S1.13-1971 Methods for the Measurement of Sound Pressure Levels
(R1986)

ANSI-S1.4-1983 Specification for Sound Level Meters

Available from: **American National Standards Institute**
11 West 42nd Street
New York, NY 10036 Tel: (212) 642-4900

ISA

ANSI/ISA S75.02 Control Valve Capacity Test Procedures, 1996

Available from: **ISA**
67 Alexander Drive
P.O. Box 12277
Research Triangle Park, NC 27709 Tel: (919) 549-8411

NATIONAL FLUID POWER ASSOCIATION (NFPA)

ANSI/(NFPA)
T3.5.28 R1-1997 Hydraulic Fluid Power — Valves — Pressure Differential Flow
Characteristic — Method of Measuring and Reporting

Available from: **NFPA**
3333 N Mayfair Road
Suite 311
Milwaukee, WI 53222-3219 Tel: (414) 778-3344

Developing and promulgating technically sound consensus standards, recommended practices, and technical reports is one of ISA's primary goals. To achieve this goal the Standards and Practices Department relies on the technical expertise and efforts of volunteer committee members, chairmen, and reviewers.

ISA is an American National Standards Institute (ANSI) accredited organization. ISA administers United States Technical Advisory Groups (USTAGs) and provides secretariat support for International Electrotechnical Commission (IEC) and International Organization for Standardization (ISO) committees that develop process measurement and control standards. To obtain additional information on the Society's standards program, please write:

ISA
Attn: Standards Department
67 Alexander Drive
P.O. Box 12277
Research Triangle Park, NC 27709

ISBN: 1-55617-653-8